

Public Notice

Notification of Discharge of Untreated Wastewater in Stokes County

The City of King had a discharge of untreated wastewater (combined with stormwater) on October 11, 2018, of an estimated 75,000 gallons from “The Farm” pumping station at the end of Rolling Green Lane in The Farm Subdivision. This discharge occurred in the afternoon of this date and lasted approximately 2 hours. This discharge was caused by the rain event from Hurricane Michael that produced a large amount of rain water runoff, inflow and infiltration. The untreated wastewater (combined with stormwater) spilled into Crooked Run Creek in the Yadkin River Basin. The pumping station continued to function during this event, but could not keep up. This notice is required by North Carolina General Statutes Article 21, Chapter 143.215C. For more information contact Scott Barrow at (336) 983-8265.