

## Public Notice

### Notification of Discharge of Untreated Wastewater in Stokes County

The City of King had a discharge of untreated wastewater (combined with stormwater) of an estimated 346,000 gallons from “The Farm” pumping station at the end of Rolling Green Lane in The Farm Subdivision. This discharge occurred on October 29, 2020 at 11:50 am and lasted until 6:30 pm. This discharge was caused by a power loss during the Hurricane Zeta event and a problem with the existing generator. The untreated wastewater spilled onto the surface and could make its way into Crooked Run Creek in the Yadkin River Basin. The generator was repaired and placed back into service. This notice is required by North Carolina General Statute Article 21, Chapter 143.215C. For more information contact Scott Barrow at (336) 983-8265.

The City of King had another discharge of untreated wastewater (combined with stormwater) of an estimated 155,700 gallons from “The Farm” pumping station at the end of Rolling Green Lane in The Farm Subdivision. This discharge occurred on October 30, 2020 at 4:00 am and lasted until 10 am. This discharge was caused by another issue with the existing generator. The untreated wastewater spilled onto the surface and could make its way into Crooked Run Creek in the Yadkin River Basin. The generator was repaired and placed back into service. This notice is required by North Carolina General Statute Article 21, Chapter 143.215C. For more information contact Scott Barrow at (336) 983-8265.