



## Public Notice

### **Notification of Discharge of Untreated Wastewater in Stokes County**

The City of King had a discharge of untreated wastewater of an estimated 95,000 gallons from “The Farm” pumping station at the end of Rolling Green Lane in The Farm Subdivision. This discharge occurred on June 16, 2024, at 10:00 pm and lasted until 3:30 pm on June 17, 2024. This discharge was caused by a force main rupture. The untreated wastewater spilled onto the surface and made its way into Crooked Run Creek in the Yadkin River Basin. The force main was repaired and placed back into service. This notice is required by North Carolina General Statute Article 21, Chapter 143.215C. For more information contact Ben Marion at (336) 983-8265.

The City of King had another discharge of untreated wastewater of an estimated 30,800 gallons from “The Farm” pumping station at the end of Rolling Green Lane in The Farm Subdivision. This discharge occurred on June 17, 2024, at 9:00 pm and lasted until 4:00 am on June 18, 2024. This discharge was caused by numerous pump failures. The untreated wastewater spilled onto the surface and made its way into Crooked Run Creek in the Yadkin River Basin. The pumps are currently being bypassed while being repaired. This notice is required by North Carolina General Statute Article 21, Chapter 143.215C. For more information contact Ben Marion at (336) 983-8265.